

Tempo Underfloor heating system

Holder**Byggelit Sverige AB**

Östersundsvägen 59, SE-836 31 Lit, Sweden

Organisation number: 556821-6740

Phone: +46 642 444 00

E-mail: info@byggelit.se , web: www.byggelit.se

Product description

Tempo underfloor heating system with 22 mm grooved flooring grade particle board for waterborne underfloor heating and floor according to assembly instructions.

Intended use

Flooring system with grooved flooring grade particle board for waterborne underfloor heating in climate class 1.

Trade name

Tempo

Approval

The product has been verified against the following sections of Boverket Building Regulations (BBR) and Boverket's regulations and general advice on the application of European design standards (Eurocodes),(EKS):

BBR

Air, General

6:21, General recommendation,
2nd paragraph
8:2433

Protective devices for preventing people from stepping through*

EKS

Design assisted by testing
Design of timber structures

Section B, EN 1990 Annex D
Section G, EN 1995-1-1

* The requirement is fulfilled when the grooved particle board is mounted

Associated documents

Monteringsanvisning för Byggelit Tempo värmegolvssystem, 2017 aug.
Tempo Fråsmall april 2016.

Control

The factory production control (FPC) is monitored by an independent inspection body.
Control agreement: 210-11-0060, Inspection body: RISE Research Institutes of Sweden AB.

When the building proprietor performs inspection at the building site, markings shall be checked to ensure that the correct products have been supplied and that they are used in accordance with the conditions in this approval and associated document.

Certificate no. SC0123-16 | 2017-09-13

RISE Research Institutes of Sweden AB | Certification
Box 857, SE-501 15 Borås, Sverige
Tel: +46 10-516 50 00
certifiering@ri.se | www.ri.se

2017-07-05



6P01832



Manufacturing place

Production control includes the following place:
Byggelit Sverige AB, Lit, Sweden.

Marking

The product is to be marked at the factory. The marking consists of a text on every product supplied and includes:

Manufacturing place

P-mark

Certification body

Product type designation

Certificate number

Durability class

Consecutive date of production

Inspection body

Byggelit Sverige AB, Lit

 GOLVVÄRME

RISE Certifiering

TEMPO

SC0123-16

P6 or P7

date

RISE

Assembly instruction shall be marked with:

Holder of certificate

P-mark

Certification body

Certificate number

Byggelit Sverige AB

 GOLVVÄRME

RISE Certifiering

SC0123-16

Basis for judgement/approval

Report 6P00315, F904921E and BMtP605029A from SP Technical Research Institute of Sweden.
Opinion 7P02671 from RISE Research Institutes of Sweden AB.

Comments

If grooved particle board P7 is mounted, the requirement for service class 2 is fulfilled.
Flooring may not be installed in service class 2.

Validity

Valid through 2022-09-12.

Johan Åkesson

Leif Lundqvist

This is a translation from the Swedish original document. In the event of any dispute as to its content, the Swedish text shall take precedence.

Certificate no. SC0123-16 | 2017-09-13

RISE Research Institutes of Sweden AB | Certification